

APPLICATION No.: 20783

TAP CLEARED

LOCATION: 194 Cove St.OWNER: Mamie DextraseMEASURES: 5/8" H lead June 3, 1925E from County St. 56.8 ft.N from S line Cove St. 7.0 ft.W from E line bldg. 2.2 ft.

✓ July 16, 1957 Renewed from curb stop to inside pit
1 lb. wiping solder
1 sidewalk cut 5' x 2' cement
Frasier F.
Silva

✓ Oct. 1, 1971 Renewed from curb stop to property line.
13 ft. - 3/4" Copper tubing

1" Copper Service

5/6/2019 Lead Service Line Replacement Program, Phase 1

Contractor P. Gioioso & Son

Type Cu, Diameter (in) 1, Water pressure 100

Distance main to curb stop (ft) 9

Distance curb stop to meter (ft) n/a

Distance curb stop to curb face (ft) 2

Depth of service (ft) 5

Total length of new pipe installed (ft) 9

Curb stop replaced: yes, size 1"

Corporation replaced: yes, size 1"

Ball valve replaced: no

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS
2/17/48		5/8	F Hersey D	2253857					

CHARGE OUTS

County Street — — — — —

