

APPLICATION No.: 20878

TAP CLEARED

LOCATION: S.E. Cor. Union & Purchase

OWNER:

MEASURES: 4"

FIRE SUPPLY
C.I.

Darling gate I. box

S from

Union

87.5 ft.

W from W line

Building

12.7 ft.

N from S line

Building

4.6 ft.

Sept. 30, 1973 Relocated 4" Gate, closer to the water main. Inserted 3 ft. of pipe in old location of gate

with two Smith Blair Cplg.

5 1/2 ft. - 4" C.I. Pipe S&S

4" Mueller Gate Valve
AB

4" Gate Box, Regular

4" Smith Blair Cplg. #441

2 - 4" leadite joints

5/8" asbestos

Measures of Mueller Gate Valve

S x S line Union St.

88.5 ft.

W x E line Purchase St.

29.3 ft.

N x S line Bldg.

4.3 ft.

W x W line Bldg.

31.9 ft.

Measures of Smith Blair cplg. for Gate

E x W line Purchase St.

27.8 ft.

E x W line Purchase St.

30.8 ft.

Measures of Smith Blair cplg. for Spacer

W x W line Purchase St.

9.4 ft.

W x W line Purchase St.

12.4 ft.

H-5

DATE

BEF.

AFT.

REMARKS

[illegible]

104-74

APPLICATION No.: 20878

TAP CLEARED

LOCATION: S.E. cor. Union and Purchase

DATE

BEF.

AFT.

REMARKS

OWNER:

F.S

MEASURES:

4"

C.I. Darling gate

S from Union

87.5

W from W line Building

12.7

N from S line Building

4.6

I.S

[illegible]

CHARGE OUTS

[illegible]