

APPLICATION No.: 20907---4"

TAP CLEARED

LOCATION: Acushnet Ave. E.S., S. of Elm

OWNER: \_\_\_\_\_

FIRE SUPPLY

MEASURES:

4"

S from Elm 67.3 ft.

E from W line Acush.Av. 15.0 ft.

S from N line bldg. 3.0 ft.

Darling gate, I.box

FIRE  
SUPPLY

March 5, 1976 Renewed from main to property line.  
in the following order by Fantoni Const.

8" x 8" x 6" Tee

1.2 ft. - 6" Ductile Pipe

1 - 6" Mueller Gate, Mech.

1.2 ft. - 6" Ductile Pipe

1 - 6" x 4" Reducer, Mech. (into old 4" pipe) (E x W line 18.6')

Measure of 6" Gate Valve:

S x S line Elm St. 66.2 ft.

E x W line Acushnet Ave. 16.4 ft.

- - -

This 6" gate is closed because the old 4"  
6" gate was closed this line has a  
leak in sidewalk.

DATE

BEF.

AFT.

REMARKS

## METER HISTORY

## CHARGE OUTS

[illegible]