

APPLICATION No.: 20910

TAP CLEARED

~~8619-1812~~

LOCATION: 787-789 S.W. Cor. Mt. Pleasant & Downey

OWNER: Herbert Varley Jr.

MEASURES:

3/4"

L lead

S from

Downey.

51.0 ft.

E from W line

Mt. Pleasant

9.1 ft.

N from S line

House

1.5 ft.

May 7, 1986 Renewed from 1 ft. outside curb stop to a point 4 ft. inside curb stop.

5 ft. - 3/4" Copper tubing 1 - 3/4" Curb Stop

1 Caldwell Stop Box, compl. 2 - 5/8" x 3/4" lead to cop adapt **XXS**

NOTE: Repaired leak on Ser. #20910 - This service was at one time tied in with tee to ser #28378 which ran along sidewalk for trailer. This tee was disconnected and above work done. May 7, 1986

3/23/93: Dug & re-set stop box

[illegible]

CHARGE OUTS

[illegible]