

APPLICATION No.: 20940

TAP CLEARED 8631-3602

LOCATION: 133-5 Bellevue St.

OWNER: Robert C. Tate

MEASURES: 5/8" H lead Oct. 7, 1925  
 W from Mina St. 386.3 ft.  
 S from N line Bellevue St. 8.8 ft.  
 W from E line house 12.8 ft.  
 S from S line house 12.0 ft.

8/1/86: Renewed from 1/2' outside curb stop to prop line.

Stock: 8 ft. 3/4" copper tubing 1 - 3/4" curb stop

1 - Caldwell stop box 2 - 3/4 x 5/8 lead to cop adapt. xxs.

=====

July 3, 1995 checked leak in cellar - Monty 10 ft. punch.

=====

11/17/97: renewed from 4' ins. curb stop to ins. cellar (12 ft. ins.  
 prop. line) Stock: 19 ft. 3/4" copper tubing, 1- 3/4x3/4 cop. to  
 cop. cplg., comp.

=====

3/5/10 - City crew renewed water service from main to curb stop

22 ft - 3/4" copper tubing; 1 - 3/4" curb stop;

1 Caldwell stop box; 1 - 5/8" x 3/4" Fig. 413;

Tap reamed. Foreman: Frank Bento

-----

DATE

BEF.

AFT.

REMARKS

8726-4616

6/26/87: TAP

REAMED

11/14/97

974605507

11/17/97

974700404

## METER HISTORY

## CHARGE OUTS

[illegible]