

Feltor Street

APPLICATION No.: 20953 - 4"

TAP CLEARED

81 LOCATION: TARKILN HILL RD. S.S. W. OF METCALF

OWNER:

MEASURES: 4" C.I.

w x Metcalf St.

72.0 ft.

n x s line Tarkiln Hill Rd.

19.0 ft.

FIRE SUPPLY

Sept. 2, 1983 Installed 4" Darling gate valve on ser. # 20953-4"
The 3" gate was broken in the closed position. This 3" gate was
left in place with guts removed.

St. cut: 6' x 3' Warr.

4" Darl. gate valve, mech. 2 - 18" pcs of 4" C.I.C.I. ductile pipe

2 - 4" Smith-Blair #441 cast cplg. #10 Caldwell gate box, compl.

4" Muel. gate valve, mech.

[illegible]

CHARGE OUTS

[illegible]