

APPLICATION No.: 20962

LOCATION: 110 Jenny Lind St E.S., S of Milton St

OWNER:

31-313

MEASURES: 3/4" Copper Original Date: 01/01/1925

S from	Milton St	72.0
W from E line	Jenny Lind St	6.6
N from S line	House	12.8

11/7/08 - Reis Asphalt renewed service from curb stop into cellar. Hired by owner - Owner charged \$155 (\$30 shut-off, \$70 inspection, \$25 meter couplings & \$30 turn-on).

Inspected by Manny Rose I II

6/10/08 - West End Water Main Rehab Contract # 4 - Perrina Const.
Renewed water service from main to a point 6 ft
6 ft - 1" copper tubing; 1 - 1" corp tap; 1 - 1" x 3/4" reducer
Inspected by Tim Ives, CDM

[illegible]

APPLICATION No.: 20962

TAP CLEARED

LOCATION: 110 Jenny Lind E.S., S. of Milton

OWNER: J.D. Cobb

MEASURES: 3/4"

S from

W from E line

N from S line

L lead

Milton

Jenny Lind

house

72.0 ft.

6.6 ft.

12.8 ft.

DATE

BEF.

AFT.

REMARKS

1/9/97

970203548

12/5/97

974905236

1/9/97: tap reamed

12/14/97

975005104

10-22-99 Tap reamed

Feb. 16, 1959 Renewed from curb stop to 4 1/2 ft. inside curb stop

4 1/2 ft. - 3/4" Copper tubing 2# wiping solder

Feb. 17, 1959 Renewed from a point 4 1/2 ft. inside curb stop to inside property line.

3 1/2 ft. - 3/4" Copper tubing 3/4" cop to cop cplg.
1# wiping solder

12/5/77 checked by F. Frasier - found no leak

Jan 9, 1997: Renewed from main to a point 1.0ft

Stock: 1.0ft 3/4" copper tubing 1-3/4x5/8 lead-cop adapt.xxs

1- 3/4 x 3/4 Fig 413

12/12/97: Renewed from 1.4' outside curb stop to curb stop. Stock:

1.4 ft. 3/4" copper tubing, 1- 3/4" curb stop, 1- #1 Caldwell stop

box, 1- 5/8x3/4 lead to copper adapt. xxs

10-22-99 DW White renewed from main 1/2 ft. outside curb

stop. Stock: 19 ft. - 3/4" Copper tubing, 1 - 3/4" Curb

Stop, 1 - 5/8" x 3/4" cop to cop cplg., comp. 1 - 5/8"

Fig. 413. DW White to maintain cut.

[illegible]

CHARGE OUTS

[illegible]