

APPLICATION No.: 20964

TAP CLEARED

LOCATION: 102 Jenny Lind E.S., N. of Hillman

OWNER: Robt. Boman

MEASURES:

 $3/4''$

N from

W from E line

S from N line

L lead

Hillman

Jenny Lind

house

301.7 ft.

6.3 ft.

8.0 ft.

March 31, 1977 Renewed from the main to a point 3 ft.
in front of the main.

3 ft. - 3/4" Copper tubing 5/8" x 3/4" lead to cop.
3/4" x 1" Fig. 413 adapt. XXS

1/10/86: Renewed from 1/2' outside curb stop to prop line.

Stock: 6ft. 4in. 3/4" copper tubing 1 - 3/4" curb stop

1 - Caldwell stop box 2 - 3/4x5/8 lead to cop. adapt. xxs.

Oct 16, 1997: Renewed from main to inside cellar(17ft ins.prop
line) Stock: 43ft 3/4" copper tubing 1-3/4" curb stop
1-caldwell stop box 1-3/4x5/8 Fig 413

6/11/08 - West End Water Main Rehab Contract # 4 - Perrina Const.

Renewed water service from main to a point 6 ft

6 ft - 1" copper tubing; 1 - 1" corp tap; 1 - 1" x 3/4" reducer

Inspected by Tim Ives, CDM

[illegible]

CHARGE OUTS

[illegible]