

APPLICATION No.: 21004

LOCATION: 55 Dudley St.

OWNER: Gladys Newsham

MEASURES: 5/8" H lead Dec. 14, 1925

E from Rod. French Blvd. (W) 48~~4~~.5 ft.

S from N line Dudley St. 9.0 ft.

E from W line house 11.3 ft.

✓ 8/16/78: Renewed 6" outside curb stop to prop. line.  
7 ft.-3/4" copper; 3/4" curb stop; 2-5/8" x 3/4" lead to  
cop. adapt. XS; Caldwell stop box;

4/6/88 Renewed from main to a point 3 ft  
3ft-3/4" copper tubing, 1-5/8x3/4 lead to cop adapt xxs  
1-5/8x3/4 Fig 413

8-17-01 Renewed from main to curb stop. Stock: 30 ft. - Copper tubing, 1 - 34/" Curb Stop, 1 - Caldwell Stop Box, 1 - 5/8"x3/4" lead to cop. adapt. XXS, 1 - 5/8"x3/4" Fig. 413. Replace 12' - 6' PVC for sewer on sidewalk.

8-21-01 Renewed from main to a point 3 ft. in front of main.  
 ✓ Stock: 3 ft. - 3/4" Copper tubing, 1 - 3/4" Corporation tap,  
 1 - 6" x 3/4" Service Saddle. Note: This service was done before  
 while digging for other service. They pull out tap off main.

BRADBURY-WARING, INC.

## TAP CLEARED

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

4/6/88

8-17-01	Tap reamed
---------	------------

reared

8814-1534

[illegible]

CHARGE OUTS