APPLICATION No.:	APPLICATION No.: 21009		TAP CLEARED			
LOCATION: 362 Bedford St.		DATE	BEF.	AFT.	REMARKS	
OWNER: Antonio G. Silveira		/			4	
MEASURES: 5/8" L lead	Dec.18,1925	1/6/12		3'30	2012-010 1451	
W from Brigham St.	199.0 ft.					
N from S line Bedford St.	9.0 ft.					
E from W line house	8.8 ft.					
1/11/12 - City crew renewed water service from main to property line 16 ft - 3/4" copper tubing; 1 -3/4" curb stop; 1 Caldwell stop box;1 -5/8" x 3/4" lead to cop adapt xxs 1 -5/8" x 3/4" Fig 413; Tap cleaned, Foreman: Frank Ben  1/11/12 - City crew repaired section of sewer service damaged while working on water service 5 ft - 6" PVC pipe; 2 - 6" Clay to PVC Fernco's Foreman: Frank Bento		; to				