

3735 Acushnet Ave APPLICATION No.: 21112 3/4" Lead

COPPER

TAP CLEARED

LOCATION:

DATE

BEF.

AFT.

REMARKS

OWNER:

COPPER

31-313

MEASURES:

3/4" L Lead May 13, 1926

S from Pembroke 3.4 ft

E from W line Acushnet Ave 8.4 ft

N from N Line house 6.0'ft

12-21-01: Renewed from main to property line .

Stock: 20ft.- 3/4" copper tubing, 1-3/4" curli stop

1-caldwell stop box. 1- 5/8" x 3/4" lead to cop

adapt. XXS, 1- 3/4" x 3/4" Fig. 413

12-21-01: Tap Reamed

7/25/2007: Tap leak repair 2007-300-5101

work order#2007-819

3/12/2018: Lead service line replacement program

Phase 1: TYPE: CU, Diameter 1: Water Pressure 60

Distance from main to curli stop --

Distance curli stop to meter 45'

Distance from curli face to curli stop 2.5'

Depth of service 4.7'

total length of new pipe installed 45'

Comment: New 1" copper length includes 3ft interior connection to water meter

3.12.2018

