APPLICATION No.: 21210	TAP CLEARED			
LOCATION: 277 Aguidneck St.	DATE	BEF.	AFT.	REMARKS
OWNER: Manuel A. Mendoza Et Ux	5/14/6	2		Reamed
MEASURES: 3/4" Copper May 19,1927			19/1/98	1999 4008855
E from Rodney French Blvd. (W) 127.5 ft.				
S from N line Aquidneck St. 9.0 ft.				
E from W line house 8.2 ft.				
Renewed from main to 1 ft. inside curb stop 5/,4/62 25 ft. of 3/4" copper tubing type K, soft. 1-3/4" cop. to cop. stop fig. 415 1-5/8" reused corp. cplg. 1 lb. wiping solder Tap reamed 1-Street out: 9' x 3 warfenite 1-sidewalk cut: 5' x 2' dirt Abraham Jakusik Hunt				
10-1-99 Renewed from main to property line. Stock: 15 ft 3/4" Copper tubing, 1 - 3/4" Curb Stop, 1 - Caldwell Stop Box, 1 - 3/4" x 3/4" lead to cop. adapt XXS, 1 - 3/4"x3/4" Fig. 413.				
6/1/01 Checked leak - water coming into basement from foundation. Checked punch by L. Souza 16 ft. punch. 7/10/01 Eric Smith renewed service from appoint 3 ft. outside prop Insp. SMalley 3/4" Copper tubing	erty lin	e to h	ouse.	