

APPLICATION No.: 21260

TAP CLEARED 8621-3315 ✓

LOCATION: 170 Ryan St.

OWNER: Harry Rosenthal

MEASURES: 5/8"

L lead

June 16, 1927

DATE 12-26-61

BEF.

AFT.

REMARKS

Reamed

E from

John St.

73.4 ft.

N from S line

Ryan St.

8.5 ft.

W from E line

house

5.8 ft.

-----  
 December 29, 1961 Renewed from  $\frac{1}{2}$  ft. outside curb stop to 2 ft. inside curb stop

2  $\frac{1}{2}$  ft. of 3/4" copper tubing

1 3/4" cop. to cop. stop

2 lbs. wiping solder

1 Caldwell stop box, complete-long

-----  
 December 26, 1961 Rewiped joint at tap. 1 lb. wiping solder.

-----  
 5/23/86: Renewed from main to a point 1.0 ft. Stock: 1.0ft.

3/4" copper tubing 1 - 3/4 x 5/8 lead to cop adapt. comp. xs

1 - 5/8 Fig. 413

=====

4-3-89 ANICE MEDEROS- COMPLAINT OF POOR PRESSURE  
 TO HER TO CALL PLUMBER- CHECK INSIDE  
 PLUMBING.

7-25-89 COMPLAINT POOR PRESSURE TOILET 3x TO FLUSH,  
 AMONG MANY HUMEROUS OTHER COMPLAINTS.

6-12-92 COMPLAINT HAH BILL- WANTS METER CHANGED!

NOTE: CRAZY LADY CALLS ABOUT ROCKS COVERING  
 STOP BOX! MARKING BOX!

BRADBURY-WARING, INC.

[illegible]

## CHARGE OUTS