

LOCATION: 161 Fair St

APPLICATION No.: 21279

TAP CLEARED

OWNER:

31-313

Aug 22, 1927

MEASURES:

E from Dartmouth St 77.5'

S from N Line Fair St 7.0'

W from E line house 6.4'

10-12-2018: Lead service line replacement program  
phase 1 TYPE CU, Diameter 1 inch, Water Pressure 90

Distance from main to curb stop 17'

Distance curb stop to meter 16.8'

Distance from curb face to curb stop 1.3'

Depth of service 3.6'

Total length of new pipe installed 16.8'

Curb stop replaced:NO Size 3/4"

Corporation replaced:NO Size 3/4"

Ball valve furnished:YES Size 3/4"

Remarks: 3/4- 1" union installed 1.0LF outside curb stop  
1" COPPER SERVICE

DATE

BEF.

AFT.

REMARKS

10/25/96: Tap ream

[illegible]