30	19	APPLICATION No.:	21293		TAP	CLEAR	RED	/
LOCATION: Smit				DATE	BEF.	AFT.	REMARKS	
OWNER: City	of New Bedfor	rd				3-23-	941202816	
MEASURES: 3**		č.1.	10-4-27			4/17/96	96160305	6
	arlg. gate om Smith							
	om W line	Liberty	96.3 ft. 8.2 ft.				4/17/96	
Jan. 22, 1965	Renewed f	rom inside won	d of D.P.W. from			200	gate only	
o outside cu								
1½ ft 3/4" 3/4" copper o								
Stop box is w	est from th	e scale 4 ft.						_
Oct 28 1075 F	Panaimad las					_		
Oct. 28, 1975 F a Repair Sleeve					_			
3" Smith Blair # Measures of					-/			
N x S li	ine Bldg. (d	carpenter & pai	nt shop)129 ft.					-
W x W li	ine Bldg.		18 ft.					_
March 23, 1994	Heavy meter co	ver was dropped d	own meter pit on top				4	-
of service, cracke	ed the pipe.	Repaired leak by	installing a 3" #226	Rockwe	I			
full circle clamp. 1 - 3" Rockwell si		l circle clamp cp	lg. 3.73-4.00 OD 7½'	' W				_
Jan. 6, 1996 Froz 1 - 3" SMith Blair	zen pipe - no 226 single	water - found spl band full circle	it in pipe in meter clamp cplg. 3.73 4	pit. 4.00 OD	71/2" W			
April 17, 1996 s	hut off at ga	te valve only - L	eak on this service	- found	3" CI	to be	completely	
made up.	Replaced by Ne	w Service # 31985	- 1 ½"				7	-/
made up.	Replaced by Ne	w Service # 31985	- 1 ½"					

METER HISTORY										
DATE	SET	SIZE	MAKE	NUMBER	READING		TEST		REMARKS	
9-29-27		3**		1833013						
	T									
					,					