

APPLICATION No.: 21297

TAP CLEARED

LOCATION: Middle, S.E. Cor. Purchase 908-912

OWNER:

MEASURES:

6"

Darlg.gate

E from

N from S line

C.I.

I. box

Purchase

Middle

10-12-27

54.3 ft.

54.3 ft.

11.0 ft.

F  
I  
R  
ES  
U  
P  
P  
L  
Y

DATE

BEF.

AFT.

REMARKS

[illegible]

## CHARGE OUTS

[illegible]



APPLICATION No.: 21297

TAP CLEARED

LOCATION: Middle St. , S.E. cor. Purchase St.

DATE

BEF.

AFT.

REMARKS

OWNER:

MEASURES:

6"

C.I.

10-12-27

Measures of 6" Gate Valve installed Aug. 27, 1984

1 - 8" x 8' x 6" Tee, mech.

3.5 ft. - 6" C.I.C.L Ductile Pipe

1 - 6" Gate Valve, mech.

1 - Gate Box, compl.

6.8 ft. - 6" C.I.C.L Ductile pipe to existing 6" piece  
outside old gate where tie in was made with 6" S.B.  
#441 cplg.

Gate rodged to tee &amp; tee truss blocked.

NOTE: Old gate & gate box left in place - they will be  
in private property.

6" Gate Valve, Mech.

E x E line Purchase St. 53.5'

N x S line Middle St. 4.0'

[illegible]

## CHARGE OUTS

[illegible]



APPLICATION No.: 21297

## TAP CLEARED

LOCATION: Middle S.E. Cor. Purchase

OWNER:

MEASURES:

6"	C.I.	10-12-27
Darlg gate	I. box	54.0
E from	Purchase	<del>54.3 ft.</del> 54.0
N from S line	Middle	<del>11.6 ft.</del> 11.7
E x E line	Bldg.	41.0
N x N line	Bldg.	11.7

NOTE: This gate left in place  
they will be in private  
property.

See sketch of service is on main pipe report

Feb. 26, 1975 Renewed from the new 8" main in Middle  
St. to a point 7 ft. from the main.

8" x 8" x 6" C.I.C.L. Class 250 Tee, M.J.

5.7 ft. - 6" C.I.C.L. Class 2 Ductile Pipe

6" Smith private gate valve, M.J.

Buffalo gate box

6" C.I.C.L. Solid Sleeve, M.J. - -

[illegible]

CHARGE OUTS.

[illegible]