

APPLICATION No.: 21318 6" DeL.

TAP CLEARED

LOCATION: ²⁰⁰ ~~100~~ Coggeshall St.

OWNER: City of N.B. Dept. of Public Works Sewer Disposal

MEASURES: 6" 6" Darl. gate DeL. I. Boxes Dec. 29, 1927
 S from Coggeshall 91.0 ft.
 E from W line Belleville Ave. 21.6 ft.
 Service from Belleville Ave. 557 ft. 6" DeL. pipe.

June 11, 1976 48" Belleville Ave. Project
 Zoppo Const. renewed from new 48" main to the
 6" gate valve:

1.6 ft. - 6" flange pipe
 1 - 6" 1/8 Bend (Mech.)
 S x S line Coggeshall St. 41.3 ft. 91.3
 E x W line Belleville Ave. 24.4 ft.
 2 ft. - 6" ductile pipe
 1 - 6" 1/8 Bend, (Mech.)
 S x S line Coggeshall St. 43.4 ft. 93.4
 E x W line Belleville Ave. 25.6 ft.
 3.1 ft. - 6" ductile pipe
 6" Mueller gate valve, mech.
 S x S line Coggeshall St. 43.4 ft. 93.4
 E x W line Belleville Ave. 29.0 ft. Insp. by A. Camara

May 23, 1996 Waste Water hit the 3" copper line that runs into this sewer disposal plant.
 Repaired with a 3" Smith Blair #226 cplg. 2.97-3.25 OD - E x E line Belleville Ave. 60 ft.
 ----- N x N line Bldg. 9 ft.

[illegible]

CHARGE OUTS

[illegible]