

(159 ON HOUSE)

APPLICATION No.: 21320

TAP CLEARED 8952-1269

LOCATION: 157 Ryan St.

OWNER: E. Alton Tripp

MEASURES: 5/8"

L lead

Copper

Jan. 12, 1928

W from

Rockdale Ave.

129.8 ft.

S from N line Ryan St.

8.0 ft.

E from W line house

2.2 ft.

12/27/89: Renewed from main to a point 19 in.
Stock: 19in 3/4" copper tubing 1-3/4x5/8 lead to
cop adapt. xs 1-3/4 x 5/8 Fig. 413

5-1-90 COMPLAINT SEEPAGE THRU CELLAR WALL AFTER
SUDDEN RAINSTORM! CLAIMS SHE HAD CELLAR
WALL SEALED 1989 AFTER BREAK @ COST TO
HER \$300 - WANTS CITY TO REIMBURSE! TO

CITY SOL.

2/10/94: RENEWED from 1/2' outside curb stop to a point 3ft
ins. curb stop Stock: 3ft 3/4" copper tubing 1-3/4" curb stop
1-Caldwell stop box 2-3/4x5/8 lead-cop adapt. xs

=====

3-21-01 Silva Const. renewed from main to property line. Stock by
Cont: 32ft. - 3/4" Copper tubing, 1-3/4" Curb Stop, 1 - Caldwell
Stop Box, 1-5/8"x3/4" lead to cop. adapt. XS, 1-5/8"x3/4" Fig. 413
Silva Const. to maintain cut. Report by B. Donovan/CDM

-over-

[illegible]

CHARGE OUTS

21320

LOCATION:

31-313

5/8"

01-02-1928

Foreman:: Bill Days

[illegible]