

S

APPLICATION No.: 21342

TAP CLEARED 88-04-0392 ✓

LOCATION: 134 Ryan St.

OWNER: Charles E. Clavin

DATE

BEF.

AFT.

REMARKS

2-10-88

reamed

MEASURES: 5/8"

L lead

May 28, 1928

W from

Reed St.

85.5 ft.

N from S line

Ryan St.

8.9 ft.

W from E line

House

5.4 ft.

 September 23, 1965 Renewed service from 6" outside curb stop to
 3 ft. inside the curb stop.

3 1/2 ft. of 3/4" copper tubing 1 3/4" cop. to cop. stop

2 lbs. wiping solder

check for leaks 1/22/88 by Silva

1/26/88 Silva checked cellar and exact

leak near meter can be fixed.

2-10-88 Renewed from main to inside cellar (16ft ins prop line)

35ft-3/4" copper tubing, 1-3/4" curb stop, 1-Caldwell stop box

1-5/8x3/4 Fig 413

Clear of Electric

[illegible]

CHARGE OUTS