

APPLICATION No.: 21343

TAP CLEARED

LOCATION: 58 Capitol St.

OWNER: Charles Chadwick

MEASURES: 5/8" H lead May 21, 1928

E from Rod.Fr.Blvd. 541.0 ft.
(W)

N from S line Capitol St. 8.6 ft.

E from W line house 8.7 ft.

5/14/07 Renewed from main to property line. Stock: 13 ft. 3/4"
 copper tubing; 3/4" curb stop; Caldwell stop box; 5/8" x 3/4"
 lead-cop adapt. XXS; 5/8" x 3/4" Fig. 413 Tap reamed Monty
 NOTE: NEW BOX 2 FT E X OLD BOX (ROOTS SHIFTED OLD BOX)

8/10/07 - Owner complaining of low pressure. Jesse Velez excavated
 to check tap, found no problem with service line, had 80 lbs. pressure
 Backfilled trench

DATE

BEF.

AFT.

REMARKS

4-6-07

9:45 2007-140-3056

5/14/07

Tap reamed

7/23/07

2007-290-7124

[illegible]