

APPLICATION No.: 21345 6" DeL.

TAP CLEARED

OK

LOCATION: 12 Johnnycake Hill

OWNER:

MEASURES: 6" DeL. Apr. 28, 1928
 6" Darling gate W. box 172.5 ft.
 S from William 172.5 ft.
 E from W line Johnnycake Hill 16.5 ft.
 S from N line Bldg. 31.0 ft.

✓ March 1976: During the install. of the 8" main pipe in William St. Johnnycake hill
 and 8" x 6" tee was installed for this service. FONTANI CONSTRUCT.

✓ Measure of 8 x 8 x 6 Tee: S x S line William St. 170.4 ft.
 E x W line Bethel St. 14.0 ft.

6" Met. Gate Valve, Mech.: S x S line William St. 170.4 ft.
 W x E line Johnnycake Hill 21.4 ft.

1.6 ft. - 6" C.I.C.L. Ductile Pipe

6" Smith Blair #441 Cplg.:

S x S line William St. 170.4 ft.
 W x E line Johnnycake Hill 19.6 ft.

- - -

F
I
R
E
S
U
P
P
L
Y

[illegible]

CHARGE OUTS

[illegible]