

APPLICATION No.: 21360

TAP CLEARED

LOCATION: 316 Maxfield E. of Emerson

OWNER:

MEASURES:

4"-

4" Darlg.

E from E line

N from

C.I.

I. box

Emerson

Bldg.

8-30-28

28.1 ft.

28.1 ft.

12.8 ft.

F
I
R
E

S

NOTE: This fire supply is interconnected with F.S. #21359 off Hillman St.

P

P

L

Y

Nov. 25, 1991 Cut out old 6" check valve in wheel alignment pit, tied with 4.5 ft. pc. of 6" ductile pipe, 2 - 6" Omni cplg.

North cplg. on 1.0 ft. pc. 6" left on 4" x 6" Increaser 2.0 ft. S x wall.

South cplg. 6.5 ft. South x wall.

New check valves to be installed on outside of bldg. in yard south from south wall.

[illegible]

CHARGE OUTS

[illegible]