

APPLICATION No.: 21364

TAP CLEARED

LOCATION: 19 Clarendon St

OWNER:

31-313

MEASURES: E X E Line Commonwealth Ave 177.4 ft
S X N Line Clarendon St 9.1 ft
E X W Line House 16.4 ft
W X W Line House 8.0 ft
S X S Line House 20.1 ft
Main to property line 31 ft
Pipe inside property 14 ft
12/14/2021 3/4 Copper Renewal
Curb stop to meter, Contractor Eric Smith
Inspected by Percy Reynolds

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

APPLICATION No.: 21364 3/4" Lead

TAP CLEARED

LOCATION: 19 Clarendon St. N. S. E. of Commonwealth

OWNER: Albert & Susan Pollard

MEASURES: $3/4"$

lead

~~5/5/39~~ 8-15-1928

E from E line

Commonwealth Ave.

177.4 ft.

S from N line

Cleendon

9.1 ft.

E from W line

House

16.4 ft.

March 22, 1971 Renewed from 6" outside curb step to a point
3 ft. inside the curb stop. Stock: 3 $\frac{1}{2}$ " - 3/4" copper tubing
3/4" Hays curb stop 2# wiping solder

Stock: 3/8" - 3/4" copper tubing
2# wiping solder

1/12/09 - City crew renewed service from main to property line
due to tap leak
32 ft - 3/4" copper tubing; 1 - 3/4" curb stop; 1 Caldwell
stop box; 1 -3/4" x 3/4" lead to cop adapt xxs; 1 -3/4" Fig 413
Tap reamed. Foreman: Danny Perry

METER HISTORY

CHARGE OUTS

[illegible]