

APPLICATION No.: 21365

LOCATION:

4415 &amp; 4417 Acushnet Ave

TAP CLEARED

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

MEASURES:

August 14, 1928

S from N line Brantwood 30.0'

E from W line Acushnet Ave 8.3'

N from N line store 3.0'

1" COPPER

12-20-17: Lead service line replacement program  
phase 1: TYPE CU, Diameter 1, Water Pressure N/A

Contractor: P. Gioioso &amp; Sons

Distance from main to curb stop N/A

Distance curb stop to meter 27.0'

Distance from curb face to curb stop 2.3'

Depth of service 4'

Total length of new pipe installed 27'

Curb stop replaced: N/A Size N/A

Corporation replaced: No Size 3/4"

Ball Valve furnished: YES Size 1"

[illegible]

### CHARGE OUTS

