

[illegible]

OWNER: John R. Noronha

H.lead May 26, 1875

Acushnet Av. 65.0 ft.

N from S line School ~~3.6~~ ~~7.1~~ ft.

W ~~E~~ from W line house 2.0 ~~1.6~~ ft.

July 3, 1965 Repaired leak at tap by cutting off 2' of excess 5/8" lead pipe; and, rewiped main joint. 1/2" tap reamed; 1 lb. wiping solder

Feb. 5, 1975 Renewed from the main to inside cellar.
22 ft. - 3/4" Copper tubing (6 ft. inside)
3/4" Curb stop Caldwell Stop Box
3/4" x 3/4" Fig. 413

[illegible]