

APPLICATION No.: 21461TAP CLEARED P330-1691LOCATION: N.W. cor 475 Prescott and LynnOWNER: A. DeBalsi

MEASURES:  $\frac{3}{4}$ " L lead May 2, 1930  
S from Lynn 8.5  
E from W line Prescoo 8.0  
N from S line house 36.7

July 29, 1983 Renewed 6" outside of curb stop to 3 ft.  
inside of curb.

4 ft. -  $\frac{3}{4}$ " copper tubing 1 -  $\frac{3}{4}$ " curb stop  
2 -  $\frac{5}{8}$ " x  $\frac{3}{4}$ " lead-cop. adapt. XXS 1-Stop box  
- - - -

1/13/12 - City crew renewed water service from main to  
property line - low pressure inside house

18 ft -  $\frac{3}{4}$ " copper tubing; 1 -  $\frac{3}{4}$ " curb stop;

1 Caldwell stop box; 1 -  $\frac{5}{8}$ " x  $\frac{3}{4}$ " lead to cop adapt

xxs; 1 -  $\frac{3}{4}$ " x  $\frac{3}{4}$ " Fig 413. Tap cleaned

Foreman: Frank Bento  
-----

DATE

BEF.

AFT.

REMARKS

1/13/12 8:00

2012-0204591



[illegible]

## CHARGE OUTS

[illegible]