

APPLICATION No.: 21470

TAP CLEARED

LOCATION: 52 S.S. Weaver W. of Field

OWNER: June I Del Tordo

MEASURES: 5/8"

L lead

July 1, 1930

W from

Field

105.2 ft.

N from S

Weaver

3.6 ft.

W from E

house

1.2 ft.

Feb. 20, 1973 Renewed from a point 12 ft. outside curb stop to a point 5 ft. inside curb stop.

17 ft. - 3/4" Copper tubing 3/4" Hays curb stop

2 lb. wiping solder Caldwell Stop Box

June 17, 1968 Renewed from 2 1/2 ft. outside curb stop to a point 4 ft. outside curb stop.

1 1/2 ft. - 3/4" Copper tubing 1 wipe joint

3/4" cop to cop cplg.

June 25, 1975 Renewed from 12 ft. outside curb stop to 19 ft. outside curb stop.

7 ft. - 3/4" Copper tubing 3/4" sweat cplg.

3/4" x 5/8" lead to copper (12 ft. E x curb stop)

adaptor XS

(19 ft. east of curb stop) - - -

June 20, 1960 Repaired leak in lead pipe by renewing with copper tubing from curb stop to a point 2 1/2 ft. outside curb stop (main pipe starts from this point)

2 1/2 ft. of 3/4" copper tubing

DATE

BEF.

AFT.

REMARKS

[illegible]

APPLICATION No.: 21470-5/8"

TAP CLEARED

LOCATION: 52 Weaver W x Field St.

OWNER:

MEASURES:

Main Pipe leak -

June 23, 1970 Renewed from a point 62 ft. W x W line Field St. to a point 64 ft. W x W line Field St.

2 ft. - 1" Copper tubing 1" cop to cop cplg.

1 wipe joint

This leak is on the 1" lead main.

Copper cplg.: W x W line Field St. 62 ft.

Wipe joint: W x W line Field St. 64 ft.

Dec. 16, 1970 small main pipe leak - Renewed from a point of 97 ft. W x W line Field St. to 101 ft.

4 ft. - 3/4" Copper tubing 3/4" coupling

1 wipe joint

Feb. 5, 1981 Small main pipe leak - Repaired leak by installing a 1" Curb Stop:

Location of 1" curb stop W x W line Field St. 34.5 ft.

5 ft. - 1" Copper tubing 1" Curb Stop Stop Box

2 - 1" x 1" lead to copper adaptor XXS


AUG 5 - 1982 - Due to installation of 6" main, renewed from main to the property line. 14 ft. - 3/4" copper; 3/4" curb stop; stop box; 5/8" x 3/4" lead-cop. adapt. XXS; corp. tap

DATE

BEF.

AFT.

REMARKS



Note: All 1" lead on Weaver St. West of Field St. was abandoned in ground. This main or lead was the main originally for 52 Weaver St.

[illegible]
