

APPLICATION No.: 21509

TAP CLEARED 8603-0033

LOCATION: 142 Carroll. St.

OWNER: Ruth R. Blume

MEASURES: 5/8" L lead Feb.28,1931

W from Palmer St. 60.0 ft.

N from S line Carroll St. 8.4 ft.

W from E line house 12.5 ft.

1/14/86: Renewed from 1 ft. outside curb stop to a point 4 ft.

Stock: 5ft. 3/4" copper tubing 1 - 3/4" curb stop
 1 - Caldwell stop box 2 - 3/4 x 5/8 lead to cop adapt. xs

8/24/12 - City crew renewed water service from main to
 curb stop due to tap leak

9 ft -3/4" copper tubing; 1 -5/8" x 3/4" Fig 413.
 Tap reamed. Foreman: Danny Perry

8/30/12 - City crew repaired tap leak
 1 - 3/4" corp tap; 1 -6" x 3/4" service saddle
 Foreman: Jarred Medeiros

DATE

BEF.

AFT.

REMARKS

8/24/12
8-24-121/13
2012-341 0091

Tap reamed

[illegible]

CHARGE OUTS