

APPLICATION No.: 21552TAP CLEARED 7/15/78LOCATION: 122 County St.OWNER: Antonio Santos

DATE

BEF.

AFT.

REMARKS

7/29/75

Reamed

MEASURES: 5/8" H lead Apr. 27, 1932N from Winsor St. 25.7 ft.W from E line County St. 4.1' ~~7.9 ft.~~S from N line bldg. 6.7 ft.

- ✓ June 30, 1965 Renewed service from 6" outside curb stop to meter inside cellar  
 11½ ft. 3/4" copper tubing  
 1 3/4" cop. to cop. stop. fig 415  
 1 lb. wiping solder  
 1 sidewalk cut: 5' x 4 cement  
 Ingersoll-Rand Compressor: ½ hr.


Abraham  
 Breton  
 Silva

- ✓ July 10, 1975 Repaired service broken by Belli Const.  
 2ft. - 3/4" Copper tubing 3/4" Curb Stop  
 2 - 5/8" x 3/4" lead to copper adaptor XS

- ✓ July 29, 1975 Renewed from the main to the curb stop.  
 28 ft. - 3/4" Copper tubing 3/4" Curb stop  
 Buffalo Stop Box 3/4" x 3/4" Fig. 413

- ✓ Jan. 16, 1981 Service thawed out. - Installed a stop box over the tap for future use. Box is buried 3" below tar in street.

BRADBURY-WARING, INC.



# 21552-5/8"

122 COUNTY ST.

[illegible]

## CHARGE OUTS

[illegible]