

APPLICATION No.: 21588

LOCATION: 195 W.S. Rodney Fr.Blvd (W) N x Willard

OWNER: N.B. Public Bath House

31-313

MEASURES: 1" H. LEAD APRIL 17, 1934

N from	WILLARD ST	60.4
E from W line	RODNEY FR.BLVD (W)	32.0
S from N line	BLDG	61.0

9/8/94: Renewed from 2ft outside curb stop to a point 1.2ft
Stock: 1.2ft 1" copper tubing 1-1" curb stop
1-1" lead-cop adapt.xxs

6/30/05 Renewed from the meter pit to a point 4 ft. outside the pit to an existing curb stop. Stock: 4 ft. 1" copper tubing; existing curb stop to tie into pit...leak was outside meter pit/

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

7/7/05

2005 27/0093

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 21588

TAP CLEARED 83-12-1044 ✓

LOCATION: 195 W.S. Rd Fr. Blvd.(W), N. of Willard

OWNER: N.B. Public Bath House

DATE

BEF.

AFT.

REMARKS

8845-2472

MEASURES:

11/9/88: TAP REAMED

9-7-94

943601919

11/9/88: REnewed from main to 1ft. outside meter pit.
 Stock: 30ft. 1" copper tubing 1-1"x1" cop to cop cplg.comp
 1 f.t outside meter pit 1-1"x1" Fig.413

1"

H Lead

Apr. 17, 1934

N from

Willard

60.4

E from W line

Rd.Fr.Bld.(W)

32.0

S from N line

Bdlg.

61.0

June 11, 1974 Renewed from a point 6½ ft. west from the
 meter pit to a point 10½ ft. westerly.
 4 ft. - 1" Copper tubing 2 wipe joints

- - -

July 8 & 9, 1974 Renewed from the meter pit to
 inside cellar.

30 ft. - 1" Copper tubing 1" Bushing x 1/4" ADAPTOR

- - -

MAR 23 1983 - Renewed from 2.0 ft. outside meter pit to a
 point 1.5 ft. easterly. 1.5 ft. - 1" copper; 1" curb stop;
 2- 1" x 1¼" lead-cop. adapt. XXS;

- - -

11/9/88: Renewed from main to 1ft. outside meter pit
 Stock: 30ft. 1" copper tubing 1-1"x1" cop to cop cplg.comp.
 1ft. outside meter pit 1-1"x1" Fig.413

[illegible]

CHARGE OUTS

[illegible]