

Service Killed

213

APPLICATION No.: 21659  
21659 C

TAP CLEARED

LOCATION: N.E. Cor. Hillman & Chancery (316 Maxfield St)

OWNER: N.B Vocational High School GYM

MEASURES:

3"	Copper	3-26-36
3" Dar. top gate	I. box	
E from Chancery		22.0 ft.
N from S line	Hillman	16.0 15.0 ft.
E from W line	Bldg	10.0 ft.

### FIRE SUPPLY

Dec. 13, 15, 1986 Repaired main break at tapping sleeve - removed the 6" x 3" tapping sleeve, 3" gate valve, 3.5 ft. - 6" main and 5 ft. of 3" copper.

Replaced with 6" x 4" tee, mech., 1 ft. - 6" ductile pipe each side of tee - tied in with

2 - 6" Rockwell #441 cplgs.

Service tied in following order:

1 ft. - 4" ductile pipe

4" Mueller gate valve, mech.

1 ft. - 4" ductile

4" x 3" reducer, mech. (lead joint ran on 3" copper at 3" mech. reducer bell)

2 ft. - 3" copper tubing

1 - 3" Smith Blair #226 clamp (4 ft. N x 4" gate)

Check out found steam leaks in cellar 11/8/90 H.P.

March 11, 2003 THIS VALVE OVER SEATS \_ DO NOT TIGHTEN ALL THE WAY. M. Rose

11/7/2011 City crew killed this service 3 ft. from 4" gate with a #441 + steel plate. Stock: 1-4" #441 with steel plate;  
1 Thrust block, cemented old 3" Service Foreman: Dana Farland



[illegible]



1/2011

## METER HISTORY

[illegible]

## CHARGE OUTS