

#455

See other card APPLICATION No.: 21677 4" Copper

LOCATION: 445 County St. W.S. Bet. Court & Morgan St.

OWNER: N.B. High School

MEASURES: 4"

4" Darlg. gate

E from

N from S line

Copper

I. box

Orchard

Court

Oct. 26, 1936

22.0 ft.

15.4 ft.

65½ ft. 4" copper pipe-Ser. from Court St.

Sept. 26, 1974 Recaulked lead joint at the main.

1 lb. lead wool supplied by Federico

Federico supplied labor, excavated & will maintain trench

Leak caused by settling of sewer trench.

- - -

Jan. 27, 75 Renewed from the new 16" main in Court St.
to a point 24.3 ft. N x S line Court St.

16" x 16" x 6" Cast iron C.L. Class 250 Tee, M.J.

6" x 4" Cast iron C.L. Reducer Class 250, M.J.

4" Smith private gate valve, M.J.

4" Brass caulking connection

4" lead joint 4" Asb. Yarn. joint

1 ft. - 6" Ci.C.L. Class 2 Ductile Pipe

8.5 ft. - 4" Cast iron C.L. Class 2 Ductile pipe

1 Buffalo Gate Box

- - -

INACTIVE SER

TAP CLEARED

DATE

BEF.


AFT.

REMARKS

[illegible]

CHARGE OUTS

APPLICATION No.: 21677

TAP CLEARED 

LOCATION: 445 County St.

OWNER: N.B. High School

MEASURES: 4"

Measures of 4" Private Gate Valve

E x E line Orchard St.	22.0 ft.
N x S line Court St.	20.3 ft.
E x W line W. El. of Bldg.	7.2 ft.
S x S line Bldg.	42.1 ft.

6" x 4" Reducer:

E x E line Orchard St.	22.0 ft.
N x S line Court St.	15.5 ft.

4" Caulking Connection

E x E line Orchard St.	22.0 ft.
N x S line Court St.	24.3 ft.

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 21677 C 4" Copper

TAP CLEARED

LOCATION: 445 County St. W.S. Court & Morgan St.

OWNER: N.B. High School

MEASURES: 4" Copper Oct. 26, 1936
4" Darl. gate I? Box
E from Orchard 22.0 ft.
N from Sline Court 15.4 ft.
65 $\frac{1}{2}$ ft. 4" copper pipe-Ser. from Court St.

This meter and service are connection of 21677 and are
by passed together.

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]