

APPLICATION No.: 21705 6" DeL

TAP CLEARED

LOCATION: 229 Coffin Ave. on Phillips Ave

DATE BEF. AFT. REMARKS

OWNER: My Bread Baking Co.

FIRE Supply

12-2-05

12-15

2005-490-8153

MEASURES: 6" 6" Darl. Gate DeL. I. box Sept. 21, 1937
 W from No. Front 65.7 ft.
 N from S line Phillips Ave. 14.8 ft.
 E from W line Building 13.5 ft.
 18 ft. 6" DeL. pipe

Dec. 17, 18 & 19 1961 Repaired a cracked 6" Fire Supply from
 Phillips Ave. by installing a Clow Repair Sleeve

1-6" "C-N" Mechanical Joint Split Repair Sleeve - Clow
 Sleeve is 9 ft. S x gate or 6 ft. N x Bldg.

FIRE SUPPLY

PDM 22082

Dec. 21, 1991 Repaired cracked 6" pipe by cutting out 4.0 ft. pc.
 of pipe (including previously installed repair sleeve)
 Installed 4.0 ft. - 6" ductile pipe & 2 - 6" Omni cplgs.
 Couplings: N x S line Phillips Ave. 4.0 ft. & 8.0 ft.

Flooding Sunbeam cellar also had to cut heat piping in sidewalk under
 concrete - was abandoned.

12/2/05 Repaired leak on F.S. with 1-6" Smith-Blain wraparound
 single band, style 226 Location of wraparound is 1 ft. S x
 line gate.

Service cut out with the main when new services were installed (34210 and 34209).
 Contractor Farland Corp, Inspector Percy Reynolds

7-31-2023

fire supply

METER HISTORY

[illegible]

CHARGE OUTS