

APPLICATION No.: 21713---5/8"

TAP CLEARED

LOCATION: E.S.Acush.Ave.(2422) N.x Homestead

OWNER: Frank Kaelesza

MEASURES:

5/8"

H.lead

Dec.10,1937

N from 1st hyd. N.x Homestead

49.0 ft.

W from E line Acushnet Ave.

6.4 ft.

S from S line house

1.0 ft.

10-8-48 Leak at tap; No Pipe Used; No stock Used.

SEP 29 1981

-Renewed from the main to the prop. line;

41.0 ft.-3/4" copper; 3/4" curb stop; stop box; 5/8" x 3/4"

Fig. 413; 5/8" x 3/4" lead-cop. adapt. XXS;

10-16-92 LEAK INSIDE PROPERTY JOINT PUNCH LOTS OF TREES +

FLOWERS!?

10/30/92: Contractor installed copper service from prop

line into cellar 1-3/4" cop-cop at prop line

DATE BEF. AFT. REMARKS

METER HISTORY

CHARGE OUTS

[illegible]