

APPLICATION No.: 21725

TAP CLEARED 9046-0056

LOCATION: 1163 Cove Rd.

OWNER: Cove Road Inc.

MEASURES: 5/8"

H lead

4/22/38

W from

County St.

85.6 ft.

S from N line

Cove Rd.

7.3

9.8 ft.

E from Wline

bldg.

6.5 ft.

Laid With Drain

Oct. 31, 1974 Renewed from the main to a point 3½ ft.
inside curb stop.

✓ 16 ft. - 3/4" Copper tubing

3/4" Curb stop

5/8" lead to copper adaptor

3/4" x 3/4" Figl 413

XXS

Caldwell Stop Box

All stock supplied by contractor except Stop Box

Due to widening of Cove Road the curb stop was moved
2½ ft. northerly.

- - -

✓ 11/12/90: Renewed from curb stop to prop line 6ft

Stock: 6ft. 3/4" copper tubing same curb stop

1-Caldwell stop box 1-3/4x3/4 lead to cop adapt. xxs

6/7/12 - Mike Andrade Const. renewed this water service
from the curb stop to the meter. Owner charged \$70 inspection
fee. Inspected by Percy - New measures attached

[illegible]

CHARGE OUTS

[illegible]

21725

APPLICATION No.:

LOCATION: 1163 Cove Rd.

OWNER: Grota's Garage

31-313

MEASURES:

New measures

W from W line County St	85.6
-------------------------	------

S from N line Cove Rd.	7.3
------------------------	-----

E from W line Building	33.5
------------------------	------

W from E line Building	24.0
------------------------	------

S from S line Building	34.0
------------------------	------

Main to Property line	14.0
-----------------------	------

Pipe inside Property	30.0
----------------------	------

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

[illegible]

[illegible]