

APPLICATION No.: 21727

TAP CLEARED

LOCATION: N.S. 1041 Sassaquin Ave. 1041 W x Acush. Ave.

OWNER: Alfred Porier

MEASURES:	3/4"	H lead	5-14-38
	W from N line	Acushnet Ave.	400.2 ft.
	S from N line	Sassaquin Ave.	7.5 ft.
	E from W line	House	10.2 ft.

-----  
Dec. 13, 2014 A.J. MEDEROS CONTRACTORS RENEWED FROM A POINT  
INSIDE CURB STOP TO INSIDE CELLAR.

12/11/2017 1" Copper Service

Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso &amp; Son

Type CU, Diameter 1in, Water pressure 60

Distance from main to curb stop (ft) 33.6

Distance from curb stop to meter (ft) N/A

Distance from curb face to curb stop (ft) 1.5

Depth of service (ft) 5

Total length of new pipe installed (ft) 33.6

Curb stop replaced: Yes size 1"

Corporation replaced: Yes size 1"

Ball valve furnished: No

