

APPLICATION No.: 21739

TAP CLEARED ✓

LOCATION: N.S. 19 Richfield W x B rownell Ave

OWNER: Johnson

DATE BEF. AFT. REMARKS

5/7/04 Tap Reamed

MEASURES:

5/8" H lead Sept. 8, 1938
W from B rownell Ave 175.6
S from N line Richfield 8.2
W from E line house 1.2

Complained of D.W. flushed hydrant 12/31/90

Removed meter 1/23/91 READ 8/19/92

Complained of D.W. 1-26-93

5/7/04 Lead service replacement - Renewed from main to prop line.
Stock: 32 ft. 3/4" copper tubnig; 3/4" curb stop; Caldwell stop
box; 5/8" x 3/4" lead-cop adapt. XXS; 5/8" x 3/4" Fig. 413

Tap reamed

5/7/04 Repaired 4 ft. main sewer 6" clay Stock: 4 ft. 8" PVC
pipe; 2 rubber cplgs; 8" clay-PVC
Repaired 8 ft of 6" sewer line on sidewalk Stock: 8 ft. 6" PVC
pipe; 2 rubber cplgs. clay-PVC

[illegible]

CHARGE OUTS

[illegible]