

APPLICATION No.: 21749

TAP CLEARED

LOCATION: S.W. cor. 833 Mt. Pleasant St. & Cox St. (box)

DATE

BEF.

AFT.

REMARKS

OWNER: Ronald Dumas

MEASURES: 5/8" H. lead 10-10-38

S	Cox St.	21.3 ft.
E from W line	Mt. Pleasant St.	8.7 ft.
N from S line	building	12.0 ft.

May 16, 1990

Removed meter from pit and installed meter in
bldg.. which is being converted to an apt.

Installed 3/4" copper tubing from meter pit to bldg.

Meter pit will stay in place and filled in.

A 5/8" x 3/4" lead to copper adapt XXS installed
in meter pit.

There is now lead from main to inside of meter pit.

G. Pitta checked for pressure - Terrible pressure.

A New Service was recommended to owner - refuses.

Insp. G. Pitta

[illegible]