

APPLICATION No.: 21775

## TAP CLEARED

LOCATION: 13 Tobey Lane

OWNER: \_\_\_\_\_

31-313

MEASURES: 6/14/39

S X May St

53.7

E X W Line Morton Ave

8.0

1" Copper Service 12/5/2017

Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso &amp; Son

Type CU, Diameter 1in, Water pressure 60

Distance from main to curb stop (ft) 8

Distance from curbstop to meter (ft) 13

Distance from curb face to curb stop (ft) 1.5

Depth of service (ft) 5.3 ft

Total length of new pipe installed (ft) 21

Curb stop replaced: Yes size 1"

Corporation replaced: Yes size 1"

Ball valve replaced: yes size 1"

Remarks: 10" water main pitted at corp, crew needed to shut  
down main and place wrap around.3/4" CU was found from meter pit to house #13 replacement  
from meter pit to main required

DATE

BEF.

AFT.

REMARKS

# METER HISTORY

## CHARGE OUTS

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

