

APPLICATION No.: 21779

## TAP CLEARED

LOCATION: 1479 Morton Ave

DATE

BEF.

AFT.

REMARKS

OWNER:

12/28/99

31-313

MEASURES: 5/27/39

N X Ivers St 80.0 ft

E X W Morton Ave 8.1 ft

S X S House 10.0 ft

1" Copper Service

12/04/2017 Lead Service Replacement Program

Phase 1, Contractor P Gioioso &amp; Son

Type CU, Diameter 1in, Water pressure 60

Distance from main to curb stop (ft) 6.6

Distance from curb stop to meter (ft) 61.0

Distance from curb face to curb stop (ft) 1.5

Depth of service (ft) 4.6

Total length of new pipe installed (ft) 67.6

Curb stop replaced: yes size 1"

Corporation replaced: yes size 1"

Ball valve furnished: yes size 1"

# METER HISTORY

## CHARGE OUTS

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

