

APPLICATION No.: 21829 5/8" H lead

TAP CLEARED

LOCATION: 116 Brownell Ave.

OWNER: Harold J. Ambush

MEASURES:	5/8"	H lead	June 4, 1940
	S from Hawthorn St.		98.0 ft.
	W from E line	Brownell Ave.	9.0 ft.
	S from N line	House	8.2 ft.

April 24, 1956 Renewed 2 ft. from a point 10 ft. outside curb stop to a point 12 ft. outside curb stop.
2 ft. - 3/4" copper tubing; 2 wipe joints;

11-9-99 DW White renewed from main to property line. Stock:
26 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop,
1 - Caldwell Stop Box, 1 - 3/8" x 3/4" lead to cop. adapt.
XXS, 1 - 5/8" x 3/4" Fig. 413.
DW. White to maintain cut.

11-22-2000 Silva Const. renewed from main to a point 3 ft. Stock:
3 ft. - Copper tubing, 1 - 3/4" x 3/4" cop to cop. cplg., comp.,
1 - 3/4" Corporation tap. Silva Const. to maintain cut.

11-22-00 Silva Const. renewed from main to a point 4.5 ft. E x main. Stock: 4.5 ft. - 3/4" Copper tubing, 1 - 3/4"x3/4" cop to cop cplg., comp. 1 - 3/4" Corporation tap, Silva Const. tapped new 8" main. Silva Const. to maintain cut.	
---	--

11-29-01 Renewed from a point 14.0' W x curb stop to a point 19.6' W x curb stop. Stock: 6ft. - 3/4" Copper tubing, 2-3/4"x3/4" cop to cop cplg., comp.

METER HISTORY									
DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

CHARGE OUTS

CHARGE OUTS

[illegible]

APPLICATION No.: _____

TAP CLEARED

LOCATION: _____

DATE

BEF.

AFT.

REMARKS

OWNER: _____

31-313

MEASURES: _____

04/19/2022: lead line replaced, from curb stop to house – renewal replaced by WC smith disturbance
#118-2022. Lucity #22-007677 Inspector Ronnie A

[illegible]