

48

325

APPLICATION No.: 21839 3/4" H lead

TAP CLEARED 852 0-1829

LOCATION: S.W. Cor. Brownell Ave. & Evelyn S.

OWNER: Miss Emma M. Sallis

MEASURES:	3/4"	H lead	July 17, 1940
	S from	Evelyn	60.1 ft.
	E from W line	Brownell Ave.	6.5 ft.
	S from S line	House	1.5 ft.

7/20/92: Renewed from 2ft inside prop line to cellar  
11ft west x stop box Stock: 3/4" copper tubing  
1-3/4x3/4 lead-cop adapt.xxs ALL STOCK BY OWNER  
CONTRACTOR-BRISTOL COUNTY EXCAVATING & LAWRENCE PLUMBING

8/26/94: Renewed from main to a point 9ft  
Stock: 9ft 3/4" copper tubing 1-3/4" curb stop 1-Caldwell  
stop box 1-3/4x3/4 lead-cop adapt.xxs 1-3/4x3/4 Fig 413

NOTE: MAIN IS 2ft INSIDE CURB GAS MAIN IS ABOUT 8FT INSIDE  
WATER MAIN ON THE EDGE OF CEMENT SIDEWALK INSTALLED ADAPTOR  
1/2FT INSIDE GAS MAIN THERE IS STILL A PIECE OF LEAD PIPE FROM  
THIS POINT TO WHERE THE CONTRACTOR LEFT OFF. L SOUZA

\*\*\*\*\*

7-12-99 Renewed from main to 3 ft. in property,  
Stock: 15 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop  
1 - Caldwell Stop Box(used old one).

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

5/20/85: TAP REAMED

8-26- 94	943406025
-------------	-----------

8/26/94:	TAP	REAMED
----------	-----	--------

7/12/99	19992900452
---------	-------------

7-12-99 Tap reamed



[illegible]