


APPLICATION No.: 21853 4" Copper

TAP CLEARED 

LOCATION: N.S. Cannon St. W. x So. Second St.

DATE

BEF.

AFT.

REMARKS

OWNER: N.B. Housing Authority Bay Village

MEASURES: 4" Copper Nov. 5, 1940
 4" Darl. Tap. Gate---Iron Box 205#
 W from So. Second 31.2 ft.
 N from S line Cannon 15.0 ft.
 E from E line Building 2.6 ft.

July 30, 1968 Renewed from a point 22 ft. S x N line
 Cannon St. to a point 25.2 ft. S x N line Cannon St.
 3.2ft. - 4" copper tubing; 2 - 4" cop to cop cplg; 1 roll
 string solder;

- - -

Feb. 2, 1951 Repaired leak on 4" copper cplg; 10'
 N_x Chimney
 2 ft. + 6" of 4" copper tubing; 3 - 4" cop to cop cplg.

- - -

METER HISTORY

CHARGE OUTS

[illegible]