

u. u.

TAP CLEARED

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

5/12/00	20002002448
---------	-------------

6-8-2000 Tap reamed

8/18/05 Renewed from curb stop to inside cellar.
SOUTH COAST BOBCAT & EXCAVATING TO MAINTAIN CUT.

11/06/07 - City crew went to ream tap, Monty checked pressure before & after the meter, both have good pressure, also found 1 valve partially opened inside house; This is internal problem. City crew did not ream
Foreman: D. Monty

[illegible]

CHARGE OUTS

[illegible]