40 19 HATU. APPLICATION No.: 22036	TAP CLEARED				
LOCATION: W.S. Mt. Pleasant St., Junction Hathaway Rd.	DATE	BEF.	AFT.	REMARKS V	
OWNER:					
MEASURES: 8" Warren Spun 3-14-44 '8" DArl. Tapg. Gate Iron Box 233#					
W from M Mt. Pleasant st.(S) 13.7 ft. N from Hathaway Rd. 7.0 ft.					
FIRE SUPPLY					
Jan. 5, 1999 Repaired leak with an 8" Smith Blair #227 Clamp -					
located E x W line Mt. Pleasant St. 23 ft.					
10-15-21: Service cut @ main & installed new 12" Line gate + hydrant gate. Contractor JLC Construction					
Inspector P. Reynolds. New Water #34146					
New water we in it	94 THE 1				

METER HISTORY							CHARGE OUTS		
DATE	SET	SIZE	MAKE	NUMBER	READING		TEST	REMARKS	
						,			
			<u> </u>						
	-								
	100								
19 11 11									
84									