APPLICATION No.:22084	TAP CLEARED			
LOCATION: 1497 Morton Ave	DATE	BEF.	AFT.	REMARKS
OWNER:	6/21/	84 Re	am	
MEASURES: 04/10/45	2/26/91 Ream			
N X S Line Meadow 17.9 ft				
E X W Line Morton Ave 9.0 ft				
S X S Line House 1.7 ft				
Additional Measures S X Center of meter box 30.3 ft				
N X Center of meter box 50.5 It				
1" Copper Service				
12/07/2017 Lead Service Replacement Program				
Phase 1, Contractor P Gioioso & Son				
Type CU, Diameter 1in, Water pressure 60		-		
Distance from main to curb stop (ft) 10.3		~~~		
Distance from curb stop to meter (ft) 22.4				
Distance from curb face to curb stop (ft) 5				
Depth of service (ft) 4.0 Total length of new pipe installed (ft) 32.7				
Curb stop replaced: yes size 1"				
Corporation replaced: yes size 1"				
Ball valve replaced: yes size 1" Remarks: no room or basement meter pit to remain				
Could not locate old corp to shut off, shut off	@ C/S			