

APPLICATION No.: 22133

DUPLICATE CARD  
TAP CLEARED ✓

LOCATION: N.S. Hathaway Rd. E x Highland St. 178.7 ft.

OWNER: Bldg. 19

MEASURES: 8" Delavaud CI 11/24/45  
1 - 8" Darl. tap. gate valve; 1 - 8: CI Gate box 233#E x E line Highland St. 178.7 ft.  
N x S line Hathaway rd. 26.6 ft.  
W x W line house 39.7 ft.

## FIRE SUPPLY

Nov. 19, 1997 Repaired crack around 8" fire supply.  
1 - 8" Ford F2 Double band clamp 9.790D 7½" W  
Clamp is N x ctr. of gate 6.0 ft.  
-----11-3-2021: Main cut out to remove service section  
of pipe with new 2" Tap + Service installed. 34146  
Contractor JLC Construction.

[illegible]

## CHARGE OUTS



APPLICATION No.: 22133

## TAP CLEARED

LOCATION: N. S. Hathaway Rd., E. of Highland St.

OWNER:

MEASURES:

8" Delavaud C1 I1 11/24/45  
1-8" Darl. tap.gate valve; 1-8" CI Gate box 233#  
E from E line Highland St. 178.7 ft  
N from S line Hathaway Rd. 26.8  
W from W line House 39.7 ft.

FIRE SUPPLY

Nov. 19, 1997 Repaired crack around 8" fire supply.  
Installed an 8" Ford F2 Double band clamp 9.79 OD 7½" W  
Clamp is N x ctr. of gate 6.0 ft.

DATE

BEF.

AFT.

REMARKS

[illegible]

## CHARGE OUTS

[illegible]