

APPLICATION No.: 22147---3/4"

TAP CLEARED

LOCATION: E.S. 3/462 Acush.Ave., N of Nye's Lane

OWNER: Samuel Dean

508 9986403

DATE

BEF.

AFT.

REMARKS

MEASURES: 3/4" H.lead March 19, 1946  
 S from 2nd hyd. from Nye's Lane 112.0 ft.  
 W from E line Acushnet Ave. 6.8 ft.  
 S from N line house 2.8 ft.

3-26-01 Nelson Cardoso renewed service from 1 ft. inside curb stop to inside cellar.. per request of new owner.

3/27/06 Renewed from main to property line

Stock: 40' of 3/4" copper tubing, 3/4" curb stop, 3/4 x 3/4 cop to cop cplg. comp, 5/8 x 3/4 Fig. 413, tap reamed

Repaired storm drain. Stock: 5' of 6" pvc, two clay to plastic ferncos 2'6"

Aug. 21, 2007: N.E. Pressure Proj. tied service into new 12" Main. 12 ft. - 1" copper tubing, 1 - 1" cop to cop cplg. comp.

3/27/06 Tap Reamed

## METER HISTORY

## CHARGE OUTS

[illegible]