

APPLICATION No.: 22149

TAP CLEARED

8645-2991

LOCATION: N.E. Cor 325 Park Ave. & Lawrence St.OWNER: Chester L. Tkol

DATE

BEF.

AFT.

REMARKS

5-27-55

Reamed

MEASURES:  $\frac{3}{4}$ "

H.L.

4-9-46

E from E line

Lawrence St.

11.5 ft.

S from N line

Park Ave.

8.0 ft.

W from W line

House

4.9 ft.

-----  
 May 27, 1955 Renewed from tap to a point 1 ft. from tap; and  
 renewed 2 ft. from a point 16 ft. from tap.  
 3 ft. of  $\frac{3}{4}$ " copper tubing 1 wiped joint  
 -----

11/5/86: Renewed from a point 14.0 ft. from 36" main to 3.0 ft.  
 inside curb stop. (Ball joint leaking under gas main--installed  
 curb stop in street --14.0 ft. from main--18.0 ft. from curb stop  
 Stock: 2 -  $\frac{3}{4}$  x  $\frac{3}{4}$  lead to cop adapt. xxs 2 -  $\frac{3}{4}$ " curb stop  
 21.0 ft.  $\frac{3}{4}$ " copper tubing 1 - curb stop.

=====

NOTE: NEW CURB STOP MEASURES-----S X N LINE PARK AVE. 10.0 ft.  
 S X S L HOUSE 31.0 ft.

[illegible]

## CHARGE OUTS

[illegible]