

APPLICATION No.: 22234

LOCATION: E.S. Padanaram 1570 Ave. S. of Cove Rd.

OWNER: Mrs. Norbert Costa

MEASURES:	3/4"	Copper	6-6-47
	N from Town line	off E.l. pad. Ave.	791.7 ft.
	W from E line	Pad. Ave.	6.5 ft.
	N from S line	House	1.5 ft.

November 21, 1957 Repaired service #2234 by installing a Smith-Blair saddle repair sleeve - Renewed $1\frac{1}{2}$ ft. at tap.
 $1\frac{1}{2}$ ft. of 1" copper tubing 1 1" x $3\frac{1}{4}$ " cop. to cop. reducer
 1 8" x 1" DC-20-7E Smith-Blair Saddle 1 1" corporation

8/13/03 Renewed from main to a point 2 ft. Stock: 2 ft.
3/4" copper tubing; 1" x 1" cop-cop cplg., comp;
1 - 8" x 1" Service Saddle (regular/blue color)

[illegible]